

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

RZAG71N7V1B*, **RZAG100N7V1B***, **RZAG125N7V1B***, **RZAG140N7V1B***,
RZAG71N7Y1B*, **RZAG100N7Y1B***, **RZAG125N7Y1B***, **RZAG140N7Y1B***,

* = , 1, 2, 3, ..., 9

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

- S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**
- S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008***
- S.I. 2016/1101: Electrical Equipment (Safety) Regulations 2016
- S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*

as amended,

following the provisions of: BS EN 60335-2-40,

* as set out in <A> and judged positively by according to the **Certificate <C>**.

** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

| | |
|-----|---------------------------|
| <A> | DAIKIN.TCF.033A15/06-2019 |
| | — |
| <C> | — |
| <D> | Daikin.TCFP.001 |
| <E> | HPi-CEproof Ltd. (NB1521) |
| <F> | D1 |
| <G> | — |
| <H> | II |

*** Daikin Europe N.V. is authorised to compile the Technical Construction File.

2P573424-3C

UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): **<K>** (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: **<L>** (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): **<M>** (°C)

Refrigerant: **<N>**

Setting of pressure safety device: **<P>** (bar)

Manufacturing number and manufacturing year: refer to model nameplate

| | | |
|------------------|-------|-----------------|
| <K> | PS | 41.5 bar |
| <L> | TSmin | -30 °C |
| <M> | TSmax | 70 °C |
| <N> | | R32 |
| <P> | | 41.5 bar |

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: **<Q>**

<Q> HPI-CEproof Ltd.
The Manor House
Howbery Business Park
Wallingford
OX10 8BA
United Kingdom

