

**UKCA – Safety declaration of conformity**

**Daikin Industries Czech Republic s.r.o.**

declares under its sole responsibility that the products to which this declaration relates:

**RZAG71N2V1B\*, RZAG100N2V1B\*, RZAG125N2V1B\*, RZAG140N2V1B\*, RZAG71N2Y1B\*, RZAG100N2Y1B\*, RZAG125N2Y1B\*, RZAG140N2Y1B\*,**

\*= , , 1, 2, 3, ..., 9

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008 \*\*\*

S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016 \*

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016 \*\*

as amended,

following the provisions of: BS EN 55014-2:2015, BS EN 55014-1:2017+A11:2020, BS EN 60335-2-40, BS EN 61000-3-11:2000, BS EN 61000-3-12:2011, BS EN 61000-3-3:2013, BS EN IEC 61000-3-2:2019,

\* as set out in <A> and judged positively by <B> according to the **Certificate <C>**.

\*\* as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

<A>	DAIKIN.TCF.033B4/03-2022
<B>	—
<C>	—
<D>	DAIKIN.TCFP.001
<E>	HPI-CEproof Ltd. (NB1521)
<F>	D1
<G>	—
<H>	II

\*\*\* DICz# is authorised to compile the Technical Construction File.

#DICz = Daikin Industries Czech Republic s.r.o.

2P573424-13G

**UKCA – Safety declaration of conformity**

continuation of previous page:

**Design Specifications of the products to which this declaration relates:**

Maximum allowable pressure (PS): **<K>** (bar)

Minimum/maximum allowable temperature (TS\*):

\* TSmin: Minimum temperature at low pressure side: **<L>** (°C)

\* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): **<M>** (°C)

Refrigerant: **<N>**

Setting of pressure safety device: **<P>** (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<b>&lt;K&gt;</b>	PS	<b>41,5 bar</b>
<b>&lt;L&gt;</b>	TSmin	<b>-30 °C</b>
<b>&lt;M&gt;</b>	TSmax	<b>70 °C</b>
<b>&lt;N&gt;</b>		<b>R32</b>
<b>&lt;P&gt;</b>		<b>41,5 bar</b>

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: **<Q>**

<b>&lt;Q&gt;</b>	HPI-CEproof Ltd. The Manor House Howbery Business Park Wallingford OX10 8BA United Kingdom
------------------	---