UKCA – Safety declaration of conformity

Daikin Industries Czech Republic s.r.o.

declares under its sole responsibility that the products to which this declaration relates:

2MXM50A2V1B9, 3MXM40A2V1B9,

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

as amended.

S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008***

S.I. 2016/1101: Electrical Equipment (Safety) Regulations 2016

S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*

following the provisions of: BS EN 60335-2-40.

<a>	DAIKIN.TCF.032E23/11-2022
	_
<c></c>	_
<d></d>	DAIKIN.TCF.PED.0146B
<e></e>	HPi Verification Services Ltd. (NB1521)
<f></f>	D1
<g></g>	_
<h></h>	П

^{*} as set out in <A> and judged positively by according to the Certificate <C>.

^{**} as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

^{***} DICz# is authorised to compile the Technical Construction File.

^{*}DICz = Daikin Industries Czech Republic s.r.o.

UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): <K> (bar)

Minimum/maximum allowable temperature (TS*):

- * TSmin: Minimum temperature at low pressure side: <L> (°C)
- * TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): <M> (°C)

Refrigerant: <N>

Setting of pressure safety device: <P> (bar)

Manufacturing number and manufacturing year: refer to model nameplate

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: <Q>

<k></k>	PS	41.7 bar
<l></l>	TSmin	-35 °C
<m></m>	TSmax	63.8 °C
<n></n>		R32
<p></p>		41.7 bar

<Q> HPi Verification Services Ltd. The Manor House **Howbery Business Park** Wallingford OX10 8BA **United Kingdom**