

UKCA – Safety declaration of conformity

Daikin Industries Czech Republic s.r.o.

declares under its sole responsibility that the products to which this declaration relates:

RXTJ30A2V1B, RXTA30C2V1B, RXTM30A2V1B, RXTM40A2V1B, RXTP25A2V1B, RXTP35A2V1B,

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016\*\*  
S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008\*\*\*  
S.I. 2016/1101: Electrical Equipment (Safety) Regulations 2016  
S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016\*  
as amended,

following the provisions of: BS EN 60335-2-40: 2003, BS EN IEC 55014-1: 2021, BS EN IEC 55014-2: 2021, BS EN IEC 61000-3-2: 2019+A1: 2021, BS EN 61000-3-3: 2013 + A2: 2021,

\* as set out in <A> and judged positively by <B> according to the **Certificate <C>**.  
\*\* as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.  
\*\*\* DICz# is authorised to compile the Technical Construction File.  
#DICz = Daikin Industries Czech Republic s.r.o.

<A>	DAIKIN.TCF.032F01/06-2023
<B>	—
<C>	—
<D>	DAIKIN.TCF.PED.0497A
<E>	HPI Verification Services Ltd. (NB1521)
<F>	D1
<G>	—
<H>	II

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): <K> (bar)

Minimum/maximum allowable temperature (TS\*):

\* TSmin: Minimum temperature at low pressure side: <L> (°C)

\* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): <M> (°C)

Refrigerant: <N>

Setting of pressure safety device: <P> (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<K>	PS	41.7 bar
<L>	TSmin	–35 °C
<M>	TSmax	63.8 °C
<N>		R32
<P>		41.7 bar

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: <Q>

<Q>	HPI Verification Services Ltd. The Manor House Howbery Business Park Wallingford OX10 8BA United Kingdom
-----	---