

UKCA – Safety declaration of conformity

Daikin Industries Czech Republic s.r.o.

declares under its sole responsibility that the products to which this declaration relates:

ERLA11D2W1, ERLA14D2W1, ERLA16D2W17,

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1101: Electrical Equipment (Safety) Regulations 2016 as amended,
S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*
S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

following the provisions of: BS EN 60335-2-40,

* as set out in <A> and judged positively by according to the **Certificate <C>**.
** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

| | |
|-----|---------------------------|
| <A> | DAIKIN.TCF.034C21/11-2022 |
| | — |
| <C> | — |
| <D> | Daikin.TCFP-0715B/1 |
| <E> | HPI-CEproof Ltd. (NB1521) |
| <F> | D1 |
| <G> | — |
| <H> | II |

UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): <K> (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: <L> (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): <M> (°C)

Refrigerant: <N>

Setting of pressure safety device: <P> (bar)

Manufacturing number and manufacturing year: refer to model nameplate

| | | |
|-----|-------|----------|
| <K> | PS | 41.5 bar |
| <L> | TSmin | –25 °C |
| <M> | TSmax | 63 °C |
| <N> | | R32 |
| <P> | | 41.5 bar |

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: <Q>

| | |
|-----|---|
| <Q> | HPI-CEproof Ltd. The Manor House Howbery Business Park Wallingford OX10 8BA United Kingdom |
|-----|---|