

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

EWSAH06UDA9W, EWSAX06UDA9W,

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016 \*\*  
S.I. 2016/1101: Electrical Equipment (Safety) Regulations 2016  
S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016 \*  
as amended,

following the provisions of: BS EN 60335-2-40,

\* as set out in <A> and judged positively by <B> according to the **Certificate <C>**.  
\*\* as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

|     |                           |
|-----|---------------------------|
| <A> | DAIKIN.TCF.034D2/01-2023  |
| <B> | —                         |
| <C> | —                         |
| <D> | DAIKIN.TCFP.0482A         |
| <E> | HPI-CEproof Ltd. (NB1521) |
| <F> | D1                        |
| <G> | —                         |
| <H> | II                        |

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): <K> (bar)

Minimum/maximum allowable temperature (TS\*):

\* TSmin: Minimum temperature at low pressure side: <L> (°C)

\* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): <M> (°C)

Refrigerant: <N>

Setting of pressure safety device: <P> (bar)

Manufacturing number and manufacturing year: refer to model nameplate

|     |       |          |
|-----|-------|----------|
| <K> | PS    | 41,7 bar |
| <L> | TSmin | -28 °C   |
| <M> | TSmax | 63 °C    |
| <N> |       | R32      |
| <P> |       | 41,7 bar |

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: <Q>

|     |                                                                                                           |
|-----|-----------------------------------------------------------------------------------------------------------|
| <Q> | HPI-CEproof Ltd.<br>The Manor House<br>Howbery Business Park<br>Wallingford<br>OX10 8BA<br>United Kingdom |
|-----|-----------------------------------------------------------------------------------------------------------|