

UKCA – Safety declaration of conformity

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

LRNUN5A7Y1*,

*= , , 1, 2, 3, ..., 9

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

as amended,

S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008***

S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*

following the provisions of: BS EN 60335-2-40, BS EN 55032: 2015, BS EN 61000-3-11: 2000, BS EN 61000-3-12: 2011, BS EN 61000-6-2: 2005,

* as set out in <A> and judged positively by according to the **Certificate <C>**.

** as set out in the Technical Construction File <D> and judged positively by <E> (Applied module <F>). <G>. Risk category <H>. Also refer to next page.

<A>	DAIKIN.TCF.035/05-2020
	—
<C>	—
<D>	Daikin.TCFP.0016A
<E>	HPI-CEproof Ltd. (NB1521)
<F>	D1
<G>	—
<H>	II

*** Daikin Europe N.V. is authorised to compile the Technical Construction File.

2P621573-4B

UKCA – Safety declaration of conformity

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): **<K>** (bar)

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: **<L>** (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): **<M>** (°C)

Refrigerant: **<N>**

Setting of pressure safety device: **<P>** (bar)

Manufacturing number and manufacturing year: refer to model nameplate

<K>	PS	120 bar
<L>	TSmin	-20 °C
<M>	TSmax	150 °C
<N>		R744
<P>		120 bar

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: **<Q>**

<Q> HPI-CEproof Ltd.
The Manor House
Howbery Business Park
Wallingford
OX10 8BA
United Kingdom