

Daikin Europe N.V.

declares under its sole responsibility that the products to which this declaration relates:

LRYEQ16A7Y1,

are in conformity with the following directive(s) or regulation(s), provided that the products are used in accordance with our instructions:

S.I. 2016/1105: Pressure Equipment (Safety) Regulations 2016**

as amended,

S.I. 2008/1597: Supply of Machinery (Safety) Regulations 2008***

S.I. 2016/1091: Electromagnetic Compatibility Regulations 2016*

following the provisions of: BS EN 60335-2-40,

* as set out in **<A>** and judged positively by **** according to the **Certificate <C>**.

** as set out in the Technical Construction File **<D>** and judged positively by **<E>** (Applied module **<F>**). **<G>**. Risk category **<H>**. Also refer to next page.

<A>	DAIKIN.TCF.023C20/06-2016
	—
<C>	—
<D>	Daikin.TCFP.001
<E>	HPi-CEproof Ltd. (NB1521)
<F>	D1
<G>	—
<H>	II

*** Daikin Europe N.V. is authorised to compile the Technical Construction File.

continuation of previous page:

Design Specifications of the products to which this declaration relates:

Maximum allowable pressure (PS): <K> (bar)

<K>	PS	40 bar
<L>	TSmin	-50 °C
<M>	TSmax	63 °C
<N>		R410A
<P>		38 bar

Minimum/maximum allowable temperature (TS*):

* TSmin: Minimum temperature at low pressure side: <L> (°C)

* TSmax: Saturated temperature corresponding with the maximum allowable pressure (PS): <M> (°C)

Refrigerant: <N>

Setting of pressure safety device: <P> (bar)

Manufacturing number and manufacturing year: refer to model nameplate

Name and address of the Notified body that judged positively on compliance with the Pressure Equipment (Safety) Regulations: <Q>

<Q>	HPI-CEproof Ltd. The Manor House Howbery Business Park Wallingford OX10 8BA United Kingdom
-----	---



Hiromitsu Iwasaki
Director
Ostend, 10th of January 2022

DAIKIN EUROPE N.V.
Zandvoordestraat 300, B-8400 Oostende, Belgium